

ADDENDUM NO. 1

TO PROSPECTIVE BIDDERS UNDER  
Wastewater Treatment Plant Upgrades  
Bamberg Board of Public Works  
Bamberg, SC

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED IN THE  
SPACE PROVIDED IN THE BID FORM IN SECTION 00 41 00

Addendum Item	Page or Drawing	Location and Description of Change										
<b>PART A - TECHNICAL SPECIFICATIONS</b>												
1.	46 23 63	<p>Modify the following:</p> <p>Revise table in paragraph 2.16.A.3, as shown below.</p> <table border="1" data-bbox="581 848 1338 1066" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th style="text-align: left;">Spare Parts</th> <th style="text-align: center;">Quantity</th> </tr> </thead> <tbody> <tr> <td>Lower bearing assembly</td> <td style="text-align: center;">1</td> </tr> <tr> <td>Complete set of wearing shoes with bolts and nuts</td> <td style="text-align: center;">1</td> </tr> <tr> <td>Motor</td> <td style="text-align: center;">1</td> </tr> <tr> <td>Belts/Sheeves, if applicable</td> <td style="text-align: center;">1</td> </tr> </tbody> </table>	Spare Parts	Quantity	Lower bearing assembly	1	Complete set of wearing shoes with bolts and nuts	1	Motor	1	Belts/Sheeves, if applicable	1
Spare Parts	Quantity											
Lower bearing assembly	1											
Complete set of wearing shoes with bolts and nuts	1											
Motor	1											
Belts/Sheeves, if applicable	1											
<b>PART B – QUESTIONS AND ANSWERS</b>												
1.		<p>Section 40 05 57.23 is missing from the specs provided.</p> <p><b>Control Valve Actuator is specified in Section 46 23 23A, paragraph 2.06.I.1.b.</b></p>										
2.		<p>Please confirm there are no AI&amp;S, BABA or other similar procurement requirements.</p> <p><b>Procurement requirements can be found in the General Conditions of the Contract Documents.</b></p>										
3.		<p>Section 46 23 23A, paragraph 2.08 A: referenced Section 40 61 13.01 does not look to include pressure gauges.</p> <p><b>The gauge shall be all 316 SST case and wetted parts, glycerin filled, 4" face, 0-100 PSIG, 1/2" NPT connection. Accuracy = +/- 1% full scale. UV resistant dial.</b></p>										
4.		<p>Section 46 23 23A, paragraph 2.16 C: Please clarify if the "Grit Underflow Control Valve" is just the Plug Valve or is it the Plug Valve and its actuator?</p> <p><b>In this instance the valve is considered the plug valve AND its actuator.</b></p>										
5.		<p>Section 46 23 63, paragraphs 2.05 A / 2.05 D.1: Hydro's classifier is either all 304 or all 316. Please clarify material of construction.</p> <p><b>All 304SS is acceptable.</b></p>										
6.		<p>Section 40 61 13.01, paragraph 2.15: Are these spares supplied by the systems integrator?</p>										

**Grit Equipment supplier shall provide only those control panel spares specified in Section 46 23 23A, paragraph 2.09 H.**

7. Contract drawing E-00-602 shows FIT-0210 connected to VCP-0210. This is not referenced in Section 46 23 23A and I-02-604 doesn't show this connection. Please clarify the power and control requirements of this device.

**Because of site conditions and location of the grit equipment a spare 15amp 120v breaker in the panel to power that flow transmitter shall be required. The flow transmitter will send a signal to the panel for connection to the Mission RTU specified per the P&IDs. There will be NO interface between the flow meter and panel other than that.**

---

This addendum shall be incorporated into and made a part of the Contract Documents

**\*\*END OF SECTION\*\***